

ANALYTICAL REPORT OF WATER SAMPLE

Name of Block-KHUNTA

Sl. No.	Panchayat	Village	Habitation	Location	Date of Testing	Parameters									Remarks	
						pH (6.5-8.5)	Conductivity in mg/ltr. (500-2000)	Turbidity, (1-5 NTU)	Chloride in mg/ltr. (250-1000)	Hardness in mg/ltr. as CaCO ₃ , (200-500)	Alkalinity in mg/ltr. as CaCO ₃ , (200-600)	Fluoride in mg/ltr. (1.0-1.5)	Iron in mg/ltr. (0.3-1.0)	TDS in mg/ltr. (500-2000)		Bact. Test, H2S Strip
1	2	3	4	5	7	8	9	10	11	12	13	14	15	16	17	18
1	DHANGHERA	DHANGHERA	DHANGHERA	Eklavya Model Residential School	07.03.22	6.98	214	0.5	36	74	90	0.24	0.09	139.0	Negative	

Remarks:- It is portable Water for above Parameters

[Signature]
08/03/2022

Lab. Chemist.

Sub-Div. Laboratory, UDALA, MBJ.